SIEMENS

Data sheet

6ES7288-2QR16-0AA0

| SIMATIC S7-200 SMART, Digital output EM DR16 16 DO, relay 2 A |
|---|
|---|

| General information | |
|--|-----------------------------------|
| Product type designation | SM DR16, DQ 16x relay/2 A |
| Supply voltage | SIM DR 10, DQ 10x 1elay/2 A |
| | 24.1/ |
| Rated value (DC) | 24 V |
| permissible range, lower limit (DC) | 20.4 V |
| permissible range, upper limit (DC) | 28.8 V |
| Input current | 440 |
| Current consumption, typ. | 110 mA |
| from backplane bus 5 V DC, typ. | 165 mA |
| Digital inputs | |
| Number of digital inputs | 0 |
| Cable length | |
| • shielded, max. | 500 m |
| • unshielded, max. | 150 m |
| Digital outputs | |
| Number of digital outputs | 16 |
| • in groups of | 4 |
| Short-circuit protection | No |
| Switching capacity of the outputs | |
| with resistive load, max. | 2 A |
| on lamp load, max. | 30 W; 30 W with DC, 200 W with AC |
| Output current | |
| for signal "1" rated value | 2 A |
| for signal "1" permissible range, max. | 2 A |
| Output delay with resistive load | |
| • "0" to "1", max. | 10 ms |
| • "1" to "0", max. | 10 ms |
| Total current of the outputs (per group) | |
| horizontal installation | |
| — up to 50 °C, max. | 10 A |
| Relay outputs | |
| Number of relay outputs | 16 |
| Rated supply voltage of relay coil L+ (DC) | 24 V |
| Reverse polarity protection | Yes |
| Current consumption of relays (coil current of all relays), max. | 150 mA |
| Switching capacity of contacts | |
| — with inductive load, max. | 2 A |
| — on lamp load, max. | 30 W |
| — with resistive load, up to 50 °C, max. | 2 A |
| — with resistive load, up to 60 °C, max. | 2 A |
| — with resistive load, max. | 2 A |
| — Thermal continuous current, max. | 2 A |
| Cable length | |
| • shielded, max. | 500 m |
| • unshielded, max. | 150 m |
| Interrupts/diagnostics/status information | |
| Diagnostics indication LED | |
| for status of the outputs | Yes |
| Potential separation | |
| Potential separation digital outputs | |
| between the channels | Yes: Relay, dry contact |
| | |

| Isolation | Isolation | | | | |
|--|--|---|--------------------------|--|--|
| Isolation tested with | 500 V AC for 1 minute for input isolation | isolation; 1500 V AC for | 1 minute for output | | |
| EMC | | | | | |
| Interference immunity against discharge of static electricity | | | | | |
| Interference immunity against discharge of static | Yes; ±4 kV contact discharge (t | | 2; ESD), ±8 kV air | | |
| electricity acc. to IEC 61000-4-2 | discharge (to IEC 801-2/IEC 10 | 000-4-2; ESD) | | | |
| Test voltage at air discharge | 8 kV | | | | |
| Test voltage at contact discharge Interference immunity against high-frequency electromagnetic field | 4 kV | | | | |
| Interference immunity against high-frequency radiation | | (to IEC 61000 4 3): 10 \// | n 000 MHz 1 80 GHz | | |
| acc. to IEC 61000-4-3 | Yes; 10 V/m, 80 to 1 000 MHz (to IEC 61000-4-3); 10 V/m, 900 MHz, 1.89 GHz, 50% ED (to IEC 61000-4-3) | | | | |
| — Frequency range of the RF radiation | 80 to 1000 MHz, 10 V/m, 1.4 to 2.0 GHz, 3 V/m, 2.0 to 2.7 GHz, 1 V/m(In the range of 87 MHz to 187 MHz, 174 MHz to 230 MHz and 470 MHz to 790 MHz: 3V/m) | | | | |
| Interference immunity to cable-borne interference | | | | | |
| Interference immunity on supply lines acc. to IEC 61000- 4-4 | Yes; ±2 kV acc. to IEC 61000-4 protective elements | Yes; ±2 kV acc. to IEC 61000-4-4, burst; surge measurements with additional protective elements | | | |
| Interference immunity on signal cables acc. to IEC 61000- 4-4 | Yes; ±2 kV (to IEC 801-4/IEC 1 | 000-4-4; Burst) | | | |
| Interference immunity against voltage surge | | | | | |
| Interference immunity on supply lines acc. to IEC 61000- 4-5 | Yes | | | | |
| asymmetric interference | ±2 kV acc. to IEC 61000-4-5, si | urge asymmetric | | | |
| Interference immunity against conducted variable disturbance induced by high-frequency fields | | | | | |
| Interference immunity against high frequency current feed acc. to IEC 61000-4-6 | Yes; 10 V, 150 kHz to 80 MHz (to IEC 61000-4-6) | | | | |
| Interference immunity against high-frequency radiation acc. to IEC 61000-4-6 | Yes; 10 V/m, with 80% amplitude modulation at 1 kHz | | | | |
| Test voltage at 80% amplitude modulation with 1kHz in the range 9 kHz to 80 MHz | 10 V | | | | |
| Emission of radio interference acc. to EN 55 011 | | | | | |
| Emission of radio interference | Interference emission to EN 50 | 081-2, testing to EN 5501 | 1, Class A, Group 1 | | |
| Limit class A, for use in industrial areas | Yes; EN 61000-6-4, interference | e emission: Intended for a | use in industrial areas. | | |
| Degree and class of protection | | | | | |
| IP degree of protection | IP20 | | | | |
| Standards, approvals, certificates | | | | | |
| CE mark | Yes; CE marking / EC Declarat | ion of Conformity | | | |
| Ambient conditions | | | | | |
| Free fall | | | | | |
| Fall height, max. | 0.3 m | | | | |
| Ambient temperature during operation | | | | | |
| • min. | 0 °C | | | | |
| • max. | 55 °C | | | | |
| horizontal installation, min. | 0 °C | | | | |
| horizontal installation, max. | 55 °C | 55 °C | | | |
| vertical installation, min. | 0 °C | | | | |
| vertical installation, max. | 45 °C | | | | |
| Ambient temperature during storage/transportation | | | | | |
| • min. | -40 °C | | | | |
| • max. | 70 °C | | | | |
| Relative humidity | | | | | |
| Operation at 25 °C without condensation, max. | 95 % | | | | |
| Dimensions | | | | | |
| Width | 45 mm | | | | |
| Height | 100 mm | | | | |
| Depth | 81 mm | | | | |
| Weights | | | | | |
| Weight, approx. | 220 g | | | | |
| Classifications | | | | | |
| | | Version | Classification | | |
| | eClass | 14 | 27-24-22-04 | | |
| | eClass | 12 | 27-24-22-04 | | |
| | Colubb | 12 | 21 27 22-07 | | |

| eClass | 9.1 | 27-24-22-04 |
|--------|-----|-------------|
| eClass | 9 | 27-24-22-04 |
| eClass | 8 | 27-24-22-04 |
| eClass | 7.1 | 27-24-22-04 |
| eClass | 6 | 27-24-22-04 |
| ETIM | 9 | EC001419 |
| ETIM | 8 | EC001419 |
| ETIM | 7 | EC001419 |
| IDEA | 4 | 3566 |
| UNSPSC | 15 | 32-15-17-05 |
| | | |

Approvals / Certificates

General Product Approval





last modified: 12/8/2024